

變電所	主變	饋線	拱位	併聯容量 (KW)	保留容量 (KW)	總併聯容量 (KW)	饋線可併網容量 (KW)	饋線最低負載 (KW)	主變最低負載 (KW)	主變可併網容量 (KW)
馬公變電所	一號主變	RA09	F12	679	133	3812	4269	1448	5996	22565
		RA14	F18	0	0		5000	1116		
		RA16	F17	772	56		4255	863		
		RA17	F16	0	0		5000	604		
		RA19	F13	51	0		4954	916		
		RA20	F11	2121	0		3091	1049		
	二號主變	RA02	F27	3490	0	9897	1859	857	6965	18058
		RA05	F25	110	0		4901	1454		
		RA07	F24	38	0		4965	618		
		RA11	F22	4437	0		1007	1023		
		RA21	F29	1784	0		3394	1700		
		RA25	F28	0	0		5000	378		
	三號主變	RA03	F32	325	0	19300	4708	876	6919	9549
		RA04	F38	2971	0		2326	657		
		RA06	F31	0	0		5000	664		
		RA08	F33	1828	1500		2004	1521		
		RA13	F35	3670	0		1697	1819		
		RA15	F37	4006	0		1395	803		
	四號主變	RA22	F34	0	5000	7013	500	578	6248	19937
		RA01	F42	15	0		4987	644		
RA12		F47	3737	0	1636		950			
RA18		F46	1194	0	3925		1720			
RA26		F43	1389	0	3750		1242			
RA28		F41	539	93	4431		1222			
尖山變電所	一號主變	RH03	L13	1508	0	24831	3643	607	4135	1787
		RH05	L14	3434	0		1910	1756		
		RH07	L15	2847	0		2438	1116		
		RH13	L12	1826	0		3357	656		
		RHA1	L11	5400	0		5140			
		RHC1	L17	9817	0		1165			
							10000			
	二號主變	RH02	L22	2679	181	25256	2426	1213	4663	1933
		RH06	L24	1510	930		2804	1259		
		RH11	L21	377	0		4661	795		
		RH14	L23	4962	0		534	1396		
		RHA0	L25	4800	0		5680			
		RHC2	L27	9817	0		1165			
	三號主變		L28			21563			4959	5552
		RH01	L33	978	0		4120	830		
		RH04	L34	1367	0		3770	1003		
		RH08	L31	1454	1500		2341	656		
		RH10	L32	1694	643		2897	2470		
		RHC0	L37	4109	0		6302			