

變電所	主變	饋線	拱位	核發容量 (kW)	保留容量 (kW)	總核發容量 (kW)	饋線可併網 容量 (kW)	饋線最低 負載 (kW)	主變最低負載 (kW)	主變可併網容量 (kW)
馬公變電所	一號主變	RA09	F12	1124	0	4391	 3988	1448	5996	 22044
		RA14	F18	10	0		 4991	1116		
		RA16	F17	815	0		 0	863		
		RA17	F16	0	0		 0	604		
		RA19	F13	89	0		 0	916		
		RA20	F11	2353	0		 0	1049		
	二號主變	RA02	F27	3136	0	9943	 2178	857	6965	 18017
		RA05	F25	110	0		 4901	1454		
		RA07	F24	36	0		 4968	618		
		RA11	F22	4441	0		 1003	1023		
		RA21	F29	1832	0		 3351	1700		
		RA25	F28	0	0		 0	378		
	三號主變	RA27	F21	388	0	18658	 0	936	6919	 10126
		RA03	F32	325	0		 4708	876		
		RA04	F38	3041	1500		 914	657		
		RA06	F31	0	0		 0	664		
		RA08	F33	2112	0		 0	1521		
		RA13	F35	3675	0		 1692	1819		
尖山變電所	一號主變	RA15	F37	4006	0	6882	 0	803	6248	 20055
		RA22	F34	4000	0		 0	578		
		RA01	F42	21	0		 4981	644		
		RA12	F47	3710	0		 1661	950		
		RA18	F46	641	0		 0	1720		
		RA26	F43	1399	0		 3741	1242		
	二號主變	RA28	F41	554	0	26203	 4501	1222	4135	 0
		RA29	F45	556	0		 4499	471		
		RH03	L13	1500	0		 3650	607		
		RH05	L14	3574	0		 1783	1756		
		RH07	L15	3293	0		 2036	1116		
		RH13	L12	1819	800		 2643	656		
	三號主變	RHA1	L11	5400	0	26175	 5140		4663	 0
		RHC1	L17	9817	0		 1165			
		RH02	L22	2314	181		 2754	1213		
		RH06	L24	2392	1085		 1870	1259		
		RH11	L21	410	1200		 3551	795		
	二號主變	RH14	L23	4775	0	20714	 702	1396	4959	 0
		RHA0	L25	4000	0		 6400			
		RHC2	L27	9817	0		 1165			
			L28							
	三號主變	RH01	L33	985	0		 4114	830		
		RH04	L34	1523	0		 3629	1003		
		RH08	L31	1514	0		 3638	656		
		RH10	L32	1430	0		 3713	2470		
	三號主變	RHC0	L37	5445	0		5100			
		RHC3	L39	9817	0		1165			

 < 1 MW

 1~3 MW

 > 3 MW

 < 5 MW

 5~10 MW

 > 10 MW